



External tobacco smoking area with 2 umbrellas to provide shelter from the rain

External yard

Rear escape route leading to street

Rear escape route leading to street

Cellar

Yard

Male WC

Female WC

Disabled Toilet

Kitchen

Stage Manager / DJ

Cooking Bar

Precious Wine Bar

Existing Basement escape stair

Staff access door only

Lobby

Fire alarm panel

Fire alarm call point

Fire alarm sounder

Carbon Dioxide Fire Extinguisher

Fire alarm sounder

Hear detector

Smoke detector

Stage

FD 30S

Denotes FD30S fire door to BS 476: part 22, to be fitted with fully compliant BS EN 1154 self closing device and using 3 rc. 25 x 45mm hinges glued and screwed to frame. Door assembly to be fitted with smoke seals and intumescent fire seals which have a BBA Certificate

Fire extinguishers shown here are based on the schedule as provided by Mr. Brian Dobson of Approved Services. Contractor to refer to that schedule dated 11 April 2013 for exact specification and signage requirements for fire extinguishers

Copyright of this drawing is held by Colin Baggett. CAD files for this drawing are not issued. This drawing is subject to a Building Control application and is not issued for construction unless it is in full compliance with the Building Regulations.

Read from Standard Engineers details see drawings

Do not scale this drawing. Do not make any alterations or additions to this drawing without the written consent of the author.

Rowbloss  
A  
13 April 2013

Drawing number: 5543/ 01/A

Drawing title: Licensing Plan  
Project: 138 The Parade, Watford WD17 7NA

Scale: 1:50 or A1  
Date: 13/04/2013

**LEGEND AND NOTES**

Licenseable activities area

Emergency lighting with emergency escape signs as appropriate with designs with symbols to BS 6499

Fire alarm call point

AFFF Fire Extinguisher

Carbon Dioxide Fire Extinguisher

Fire alarm sounder

Hear detector

Smoke detector

FD 30S

Denotes FD30S fire door to BS 476: part 22, to be fitted with fully compliant BS EN 1154 self closing device and using 3 rc. 25 x 45mm hinges glued and screwed to frame. Door assembly to be fitted with smoke seals and intumescent fire seals which have a BBA Certificate

Fire extinguishers shown here are based on the schedule as provided by Mr. Brian Dobson of Approved Services. Contractor to refer to that schedule dated 11 April 2013 for exact specification and signage requirements for fire extinguishers

Copyright of this drawing is held by Colin Baggett. CAD files for this drawing are not issued. This drawing is subject to a Building Control application and is not issued for construction unless it is in full compliance with the Building Regulations.

Read from Standard Engineers details see drawings

Do not scale this drawing. Do not make any alterations or additions to this drawing without the written consent of the author.

Rowbloss  
A  
13 April 2013

Drawing number: 5543/ 01/A

Drawing title: Licensing Plan  
Project: 138 The Parade, Watford WD17 7NA

Scale: 1:50 or A1  
Date: 13/04/2013

Fire exit doors should have only one simple fastening without the use of a key in the direction of escape or be fastenings

Fire detection and fire alarm systems to be installed to BS 5836

Fire extinguishing installations and equipment on premises to be installed to BS 5836

Fire detection and fire alarm systems are as generally modified to and added as appropriate

The locations of the fire extinguishers are as generally modified to and added as appropriate

Gas supply is cut off when the fire alarm is activated

Music to the restaurant is cut off when the fire alarm is activated

The night club's fire alarm is to be linked to the office and the basement accommodation

This drawing is subject to a Building Control application and is not issued for construction unless it is in full compliance with the Building Regulations.

Read this drawing with Basement Plan 5343/02.

Some fire fighting equipment, emergency lighting and fire alarm are already installed